



Installation and Operation Manual

Back-UPS[®] BR1200G-GR/BR1500G-GR

Inventory




Safety




This unit is intended for indoor use only.
Do not operate this unit in direct sunlight,
in contact with fluids, or where there is
excessive dust or humidity.

Connect the battery


1




2




3



4



5



Charge the battery for at least 16
hours before use.

PowerChute[®] Personal Edition Software

Overview

PowerChute Personal Edition Software allows you to use your computer to access additional power protection and management features of the Back-UPS.

Using PowerChute, you can:

- Preserve work in progress during a power outage by putting your computer into Hibernate mode. When the power returns, the computer will appear exactly as it did before the power outage.
- Configure the Back-UPS management features, such as power-saving outlets, shutdown parameters, audible alarms, and more.
- Monitor and view the status of the Back-UPS, including the estimated runtime, power consumption, power event history, and more.

Available features will vary by Back-UPS model and operating system.

If you choose not to install PowerChute, the Back-UPS will still provide backup power and power protection to connected equipment. However, you will only be able to configure a limited number of features using the display interface.

Compatibility

PowerChute is compatible with Windows operating systems only. For a detailed list of supported operating systems, go to www.apc.com, select **Software & Firmware**.

For Mac operating systems, we recommend using the native shutdown application (within System Preferences) which recognizes your battery backup and allows you to configure shutdown of your system during power outages. To access this application, connect a USB cable from the Back-UPS DATA PORT (POWERCHUTE PORT) to a USB port on your computer, and see the documentation provided with your computer.

Installation

Connect the Back-UPS to a computer using a USB cable. Plug one end into the POWERCHUTE PORT on the rear panel of the Back-UPS and the other into a USB port on your computer.

Insert the PowerChute CD into your computer and follow the on-screen instructions. If your Back-UPS did not come with a PowerChute CD, download the software from www.apc.com, select **Software & Firmware**.

Connect the equipment

Battery Backup and Surge Protected outlets



When the Back-UPS is receiving input power, the Surge Protection only outlets and the Battery Backup with Surge Protection outlets will supply power to connected equipment. During a power outage or other utility problems, only the Battery Backup outlets receive power for a limited time from the Back-UPS.

Connect equipment such as printers, FAX machines, scanners, or other peripherals that do not need battery backup power to the Surge Protection Only outlets. These outlets provide full time protection from surges even if the Back-UPS is switched off.

Master and Controlled outlets

To conserve electricity, when the device connected to Master Outlet goes into Sleep or Standby mode, or turns off, the Controlled by Master device(s) will shut down as well, saving electricity.

Connect a master device, such as a desktop computer or audio/visual receiver to the Master outlet. Connect peripheral devices such as a printer, speakers, or a scanner to the Controlled by Master outlets.



| | |
|--|---|
| 1 USB and Serial Data port | To use PowerChute Personal Edition, connect the supplied USB software cable or serial cable. |
| 2 Telephone ports | Connect a telephone cable to the In port, and a modem to the Out port. |
| 3 Ground screw | Connect the ground wire from another surge suppression device such as a network or data line surge protector to the ground screw on the Back-UPS. |
| 4 Surge Protection outlets, Controlled by Master outlet | These outlets provide surge protection during a power outage. These outlets will disconnect from A/C power during a power outage, or in the event that the Master outlet goes into Sleep mode. |
| 5 Surge Protection outlets | These outlets provide full-time surge protection, when the unit is turned on or off. Connect a printer, scanner or other devices that do not require battery backup protection. |
| 6 AC Power Cable | Connect the Back-UPS to A/C power. |
| 7 Battery Backup outlets with Surge Protection | During a power outage or other utility problems, these outlets provide power from the Back-UPS battery. Connect critical equipment such as desktop computer, computer monitor, modem or other data sensitive devices to these outlets. |
| 8 Battery Backup, Controlled by Master outlet with Surge Protection | During a power outage or other utility problems, these outlets provide power from the Back-UPS battery. These outlets will disconnect from A/C power during a power outage, or in the event that the Master outlet goes into Sleep mode. Connect critical equipment such as desktop computer, computer monitor, modem or other data sensitive devices to these outlets. |
| 9 Master outlet | Connect the master device to this outlet, in most scenarios, this will be the main computer. |
| 10 Gigabit Ethernet surge-protected ports | Use an Ethernet cable to connect a modem to the IN port, and a computer to the OUT port. |
| 11 External Battery Pack connector | Connect an external battery pack to provide additional battery backup runtime. |

BR1500G-GR model only

Operation

Power-Saving Function



To conserve electricity, configure the Back-UPS to recognize a Master device, such as a desktop computer or an A/V receiver, and Controlled peripheral devices, such as a printer, speakers, or a scanner. When the Master device goes into Sleep or Standby mode, or is switched OFF, the Controlled device(s) will be switched off as well, saving electricity.

Enable the Power-Saving function. Press and hold MUTE and DISPLAY simultaneously for two seconds. The Back-UPS will beep to indicate that the feature is enabled. The leaf icon on the display will illuminate.

Disable the Power-Saving function. Press and hold MUTE and DISPLAY simultaneously for two seconds. The Back-UPS will beep to indicate that the feature is disabled. The leaf icon on the display will go dark.

Setting the threshold. The amount of power used by a device in Sleep or Standby mode varies between devices. It may be necessary to adjust the threshold at which the Master outlet signals the Controlled outlets to shut down.

1. Ensure a master device is connected to the Master outlet. Put that device into Sleep or Standby mode, or turn it OFF.
2. Press DISPLAY and MUTE simultaneously and hold for six seconds, until the leaf icon flashes three times and the Back-UPS beeps three times.
3. The Back-UPS will now recognize the threshold level of the Master device and save it as the new threshold setting.

Power-Saving Display

The display interface can be configured to be continuously illuminated, or to save energy, it can be configured to go dark after a period of inactivity.


1. Full Time Mode: Press and hold DISPLAY for two seconds. The display will illuminate and the Back-UPS will beep to confirm the Full-Time mode.
2. Power-Saving Mode: Press and hold DISPLAY for two seconds. The display will go dark and the Back-UPS will beep to confirm the Power-Saving mode. While in Power-Saving Mode, the display will illuminate if a button is pressed, it goes dark after 60 seconds of no activity.

Unit sensitivity

Adjust the sensitivity of the Back-UPS to control when it will switch to battery power; the higher the sensitivity, the more often the Back-UPS will switch to battery power.

1. Ensure the Back-UPS is connected to A/C power, but is OFF.
2. Press and hold the POWER button for six seconds. The LOAD CAPACITY bar will flash on and off, indicating that the Back-UPS is in programming mode.
3. Press POWER again to rotate through the menu options. Stop at selected sensitivity. The Back-UPS will beep to confirm the selection.

Low sensitivity



156-300 Vac

Input voltage is extremely low or high. (Not recommended for computers.)

Medium sensitivity (Default)



176-294 Vac

The Back-UPS frequently switches to battery power.

High sensitivity



176-288 Vac


The connected equipment is sensitive to voltage fluctuations.

Front Panel Buttons and Display Interface

Use the three buttons on the front panel of the Back-UPS and the display interface to configure the Back-UPS.

Front panel

- ① Mute button
- ② Power On/Off button
- ③ Display button
- ④ Display interface



On Line—The Back-UPS is supplying conditioned A/C power to connected equipment



Power-Saving—Master and Controlled outlets are enabled, saving power when the master device goes into sleep or standby mode



Load Capacity—The load is indicated by the number of sections illuminated, one to five. Each bar represents 20% of the load.



Battery Charge—The battery charge level is indicated by the number of sections illuminated. When all five blocks are illuminated, the Back-UPS is at full charge. When one block is filled, the Back-UPS is near the end of its battery capacity, the indicator will flash and the Back-UPS will beep continuously.



Overload—The power demand from the load has exceeded the capacity of the Back-UPS.



Event—The event counter shows the number of events that occurred that caused the Back-UPS to switch to on-battery operation.



Automatic Voltage Regulation—The Back-UPS can compensate for high or low input voltage.



When illuminated, the Back-UPS is compensating for low input voltage.



When illuminated, the Back-UPS is compensating for high input voltage.



Input voltage.



Output voltage.



System Faults—The system has a fault. The fault number will illuminate on the display interface. See “System Faults” on page 6.



Mute—If the line through the speaker icon is illuminated, the audible alarm has been turned off.



Replace Battery—The battery is not connected or is nearing the end of its useful life. Replace the battery.



On Battery—The Back-UPS is supplying battery backup power to the connected equipment, it will beep four times every 30 seconds.

Warnings and System Faults

Audible Warnings

| | |
|--|---|
| Four Beeps Every 30 Seconds | Back-UPS is running on battery. You should consider saving any work in progress. |
| Continuous Beeping | Low battery condition and battery run-time is very low. Promptly save any work in progress, exit all open applications, and shut down the operating system. |
| Continuous tone | Battery Backup outputs are overloaded. |
| Chirps for 1 Minute every 5 hours | Battery fails the automatic diagnostic test and should be replaced. |

Warning Icons

If these icons are illuminated...

This may be the problem.




The Back-UPS is operating on A/C power, but is overloaded. Disconnect one of the items connected to the Back-UPS. If the Overload icon stops flashing, the Back-UPS is no longer overloaded and will continue to operate normally.



The Back-UPS is operating on battery power, but is overloaded. Disconnect one of the items connected to the Back-UPS. If the Overload icon stops flashing, the Back-UPS is no longer overloaded and will continue to operate normally.




The Back-UPS is operating on A/C power, but the battery is not functioning properly. Contact APC Customer Service to order a replacement battery. See "Replacement Battery" on page 8.



The Back-UPS is operating on battery power and the battery power is getting low. Shut down all connected equipment to avoid losing unsaved data. When possible, connect the Back-UPS to A/C power to recharge the battery.













System Faults

The Back-UPS will display these fault messages. Contact APC Technical Support.



| | |
|-------------------------------------|---|
| F01 On-Battery Overload | Turn the Back-UPS off. Disconnect non-essential equipment from the Battery Backup outlets and the turn Back-UPS on. |
| F02 On-Battery Output Short | Turn the Back-UPS off. Disconnect non-essential equipment from the Battery Backup outlets and the turn Back-UPS on. |
| F03 On-Battery Xcap Overload | Faults F03-F09 cannot be corrected by the user. Contact APC Technical Support for assistance. |
| F04 Clamp Short | |
| F05 Charge Fault | |
| F06 Relay Welding | |
| F07 Temperature | |
| F08 Fan Fault | |
| F09 Internal Fault | |

Function Button Quick-Reference

| Function | Button | Timing (seconds) | UPS Status | Description |
|--|---|------------------|------------|---|
| Power | | | | |
| Power On |  | 0.2 | Off | Press POWER to start receiving input A/C power. If A/C input power is not available, the Back-UPS will run on battery power. |
| Power Off |  | 2 | On | The Back-UPS is not receiving input A/C power, but is providing surge protection. |
| Display | | | | |
| Status Inquiry |  | 0.2 | On | Verify the status or condition of the Back-UPS. The LCD will illuminate for 60 seconds. |
| Full-Time/Power-Saving mode |  | 2 | On | The LCD will illuminate and the Back-UPS will beep to confirm the Full-Time mode. The LCD will go dark and the Back-UPS will beep to confirm the Power-Saving mode. While in Power-Saving Mode, the LCD will illuminate if a button is pressed, then goes dark after 60 seconds of no activity. |
| Mute | | | | |
| Event Specific |  | 0.2 | On | Disable any audible alarms caused by an event. |
| General Status Enable/Disable |  | 2 | On | Enable or disable the audible alarms. The Mute icon will illuminate and the Back-UPS will beep one time. The Mute function will not activate unless the Back-UPS is operating on battery power. |
| Sensitivity | | | | |
| Sensitivity |  | 6 | Off | The Load Capacity icon will blink, indicating that the Back-UPS is in programming mode. Use the POWER button to scroll through Low, Medium, and High, stop at selected sensitivity. The Back-UPS will beep to confirm selection. See Configuration for details. |
| Master/Controlled outlet Enable/Disable | | | | |
| Master/Controlled outlet Enable/Disable |  | 2 | On | The leaf icon will go dark indicating that the Master Outlet feature is disabled or illuminate to indicate the Master Outlet feature is enabled. The Back-UPS will beep once. |
| Master/Enable Threshold Calibration | | | | |
| Master/Enable Threshold Calibration |  | 6 | On | While calibrating the threshold setting, the device connected to the Master Outlet should be turned off or placed in Standby or Sleep mode. Upon completion, Power-Saving icon will flash 3 times and beep 3 times. |
| Self-Test (manual) | | | | |
| Self-Test (manual) |  | 6 | On | The Back-UPS will perform a test of the internal battery. Note: This will happen automatically when the Back-UPS is turned ON. |
| Event Reset | | | | |
| Event Reset |  | 0.2 | On | When the Event screen is visible, press and hold DISPLAY, then press POWER, to clear the utility failure event counter. |
| Fault Reset | | | | |
| Fault Reset |  | 2 | Fault | After a fault has been identified, press POWER to remove the visual indication and return to standby status. |

Troubleshooting

| Problem | Possible Cause | Corrective Action |
|--|--|--|
| Back-UPS will not turn on. | The Back-UPS is not connected to A/C power. | Ensure that the Back-UPS is securely connected to an A/C outlet. |
| | The circuit breaker has been tripped. | Disconnect non-essential equipment from the Back-UPS. Reset the circuit breaker. Re-connect equipment one item at a time. If the circuit breaker is tripped again, disconnect the device that caused the trip. |
| | The internal battery is not connected. | Connect the battery. |
| | The A/C input voltage is out of range. | Adjust the transfer voltage and sensitivity range. |
| The Back-UPS does not provide power during a A/C power outage. | Ensure that essential equipment is not plugged into a SURGE ONLY outlet. | Disconnect equipment from the SURGE ONLY outlet and re-connect to a Battery Backup outlet. |
| The Back-UPS is operating on battery power, while connected to A/C power. | The plug has partially pulled out of the wall outlet, the wall outlet is no longer receiving A/C power, or the circuit breaker has been tripped. | Ensure that the plug is fully inserted into the wall outlet. Ensure that the wall outlet is receiving A/C power by checking it with another device. |
| | The Back-UPS is performing an automatic self test. | No action is necessary. |
| | The A/C input voltage is out of range, the frequency is out of range, or the waveform is distorted. | Adjust the transfer voltage and sensitivity range. |
| The Back-UPS does not provide the expected amount of backup time. | Battery Backup outlets may be fully or improperly loaded. | Disconnect non-essential equipment from the Battery Backup outlets and connect the equipment to SURGE ONLY outlets. |
| | The battery was recently discharged due to a power outage and has not fully recharged. | Charge the battery cartridge for 16 hours. |
| | The battery has reached the end of its useful life. | Replace the battery. |
| The REPLACE BATTERY indicator is illuminated. | The battery has reached the end of its useful life. | Replace the battery. |
| The OVERLOAD indicator is illuminated. | The equipment connected to the Back-UPS is drawing more power than the Back-UPS can provide. | Disconnect non-essential equipment from the Battery Backup outlets and connect the equipment to SURGE ONLY outlets. |
| The SYSTEM FAULT indicator is illuminated, all the front panel indicators are flashing. | There is an internal fault. | Determine which internal fault message is displayed by matching the number displayed on the LCD with the corresponding Fault Message (see System Faults) and contact APC Technical Support. |
| Power is not supplied to some outlets. | Power to the Controlled outlets has intentionally been turned off. | Confirm that the correct peripherals are connected to Controlled outlets. If this feature is not desired, disable the Power-Saving Master and Controlled outlets. |
| The Controlled outlets are not supplying power, even though the Master device is not in sleep mode. | The Master Outlet threshold may be incorrectly set. | Adjust the threshold when the Master outlet signals the Controlled outlets to shut down. |

Specifications

| Model | BR1200G-GR | BR1500G-GR |
|------------------------------|--|--------------------|
| VA | 1200 VA | 1500 VA |
| Maximum Load | 720 W | 865 W |
| Nominal Input Voltage | 230 V | |
| Online Input Voltage Range | 176 V- 294 V | |
| Automatic Voltage Regulation | 188 V- 216 V +11.2% 252 V- 282 V -11.2% | |
| Frequency Range | 50/60 Hz \pm 1 Hz | |
| On-battery wave shape | Step-approximated sine-wave | |
| Typical Recharge Time | 8 hours | |
| Transfer Time | 10 ms, maximum | |
| Operating Temperature | 0° to 40° C (32° to 104° F) | |
| Storage Temperature | 5° to 45° C (23° to 113° F) | |
| Unit Dimensions | 30.1 \times 11.2 \times 39 cm (11.9 \times 4.4 \times 15.3 in) | |
| Unit Weight | 12.8 kg (28.2 lbs) | 13.4 kg (29.5 lbs) |
| Interface | Serial, USB | |
| On-Battery Runtime | Go to: www.apc.com | |
| Replacement Battery | The battery cartridge typically lasts 3 to 6 years. Environmental factors impact battery life. High temperatures, poor quality A/C power, and frequent, short duration discharges will shorten battery life. To order replacement battery cartridge APCRBC124, refer to the APC Web site, www.apc.com . Recycle used battery cartridges. | |

APC Customer Support

Internet www.apc.com

Telephone +1 888 272 3858

Warranty

The standard warranty is two (2) years from the date of purchase. APC standard procedure is to replace the original unit with a factory reconditioned unit. Customers who must have the original unit back due to the assignment of asset tags and set depreciation schedules must declare such a need at first contact with an APC Technical Support representative. APC will ship the replacement unit once the defective unit has been received by the repair department, or cross-ship upon the receipt of a valid credit card number. The customer pays for shipping the unit to APC. APC pays ground freight transportation costs to ship the replacement unit to the customer.

Service

If the unit requires service, do not return it to the dealer. Follow these steps:

1. Review the TROUBLESHOOTING section of the manual to eliminate common problems.
2. If the problem persists, contact APC Customer Support through the APC Web site, **www.apc.com**.
 - a. Note the model number and serial number and the date of purchase. The model and serial numbers are located on the rear panel of the unit and are available through the LCD display on select models.
 - b. Call APC Customer Support and a technician will attempt to solve the problem over the phone. If this is not possible, the technician will issue a Returned Material Authorization Number (RMA#).
 - c. If the unit is under warranty, the repairs are free.
 - d. Service procedures and returns may vary internationally. Refer to the APC Web site for country specific instructions.
3. Pack the unit properly to avoid damage in transit. Never use foam beads for packaging. Damage sustained in transit is not covered under warranty. **For the UPS, always DISCONNECT THE BATTERY before shipping in compliance with U.S. Department of Transportation (DOT) and IATA regulations.** The battery may remain in the unit.
4. Write the RMA# provided by Customer Support on the outside of the package.
5. Return the unit by insured, pre-paid carrier to the address provided by Customer Support.